
SUBSTATION DIGITAL TWIN

LEVERAGING IEC 61850 AND MACHINE LEARNING TO ACHIEVE ADVANCED
MONITORING AND SIMULATION OF SUBSTATION SYSTEMS

André Naumann



IEC 61850 Global
2019 14-18 October 2019
London, UK

Substations today

Automated substation tasks

- Protection according to fixed parameter sets
- Tap changing
- Some adaptive protection functions
- Report everything to the control center and wait for commands

Limited Intelligence: Dull continuation of current operation state in case of communication loss



Existing Computing power in Substations

What's the point?

- Increasing complexity of energy systems
 - Connecting different infrastructures
 - Increasing number of system components
 - Higher dynamics in power systems
- Need for increased safety and security

Use decentralized computing power for

- More intelligence and automation in the substation
- Discharging the control centre from data load
- Making things easier for operators



The toolbox

Digital Twin

- Power network simulation
- HIL simulator

Measurement data

1. DT pre processor

State estimator

2. DT model optimizer

Energy system model
(*Dynamic Digital Mirror*)

3. DT post processor

Consistency indicator



Artificial Intelligence

- Python based AI tools
- Pattern recognition
- Time series forecast

```
File Edit Format Run Options Windows Help
from TreeMachine import *


Sherman = TreeMachine()
FileName = "Corpus.txt"

print "Reading from " + FileName + "..."
FileInput = open(FileName)
for Line in FileInput:
    Sherman.FeedInString(Line)
print "Finished reading from file.\n"

#Next, read from user.
print "Enter text:"
UserInput = raw_input()
while len(UserInput) > 0:
    if UserInput[0] == "#": # A user command.
        UserCommand = UserInput[1:]
        Sherman.PrintSelf(UserCommand, 0.05)
    else:
        Sherman.FeedInString(UserInput)
        Sherman.PrintPositions()
    print "meat?"
    UserInput = raw_input()
print "IT'S OVER"
```

Standard based information exchange

- IEC 61850
- IEC 61970 (CIM)



The (Dynamic) Digital Twin

Definitions

- A Digital Twin is the **digital representation** of a unique asset (product, machine, service, etc.), that compromises its **properties, condition and behaviour** by means of models, information and data.



[R. Stark, S. Kind, and S. Neumeyer, "Innovations in digital modelling for next generation manufacturing system design," CIRP Annals, vol. 66, no. 1, pp. 169–172, 2017]

- Digital Twins are **software-based abstractions** of complex physical systems or objects which are **connected via a communication link** to the real object through a continuous data flow from the real world.

[Christoph Brosinsky, Rainer Krebs, Dirk Westermann, "Recent and Prospective Developments in Power System Control Centers: Adapting the Digital Twin Technology for Application in Power System Control Centers," in *Proceedings Energycon 2018, Limassol, Cyprus*, pp. 1–6]

- Digital twins contain the individual, virtual representation of a physical object or process, using data from the physical object for different **intelligent use cases**.


[R. Klostermeier, S. Haag, and A. Benlian, "Digitale Zwillinge – Eine explorative Fallstudie zur Untersuchung von Geschäftsmodellen," HMD, 2018]




The (Dynamic) Digital Twin

Features

- A DT makes it possible to reflect the physical conditions
 - In real-time (even faster)
 - → Exact knowledge of your system/device state
- Behavioral forecast
 - Possibility of identifying problems before they occur
 - Identifying needs for maintenance
 - Identifying countermeasures in advance
- A dynamic DT supports dynamic modeling
 - Constantly running modelling engine
 - Describes the dynamic system behavior,
- Access to non-measurable parameters (using analytical algorithms or other technologies)




<https://d3i71xaburhd42.cloudfront.net/e69931937397ce6051dcf2771402f6dba9efd3a1/21-Figure4-1.png>




Decentral organization of system operation calculations

Decentral Digital Twin (Station level)



Central Digital Twin (Electric Grid)



Digital Substation


Electric Grid

- Aggregation
- Selection
- Preprocessing

Digital Substation

Dynamic Digital Mirror of Substation

Decentral Digital Twin (Station & Nearby grid)



Decentral application of

- Digital twins and
- Artificial Intelligence

The (Dynamic) Digital Twin

Use cases in the energy system and substation


- Data preprocessing
 - Reduction of data load
 - Usage of system state indicators
- Accurate Models of system and its components
 - Real time simulation (rapid system analysis and control feedback using RTU and PMU sensor data)
 - For standard simulation
 - Higher level analyses
- DT-based Recognition of anomalies
 - Data manipulation
 - Model insufficiency
 - implausible Data from control center




The (Dynamic) Digital Twin

Use cases in the energy system and substation

- Providing substitute values (in case of missing/wrong measurements)
- Separated/islanded Operation
 - Substitute values for control center information
 - Autonomous Operation
 - Resynchronization of system state parameters after reconnection
- Augmentation of predictability of plant starts considering multiple objectives (time, output, emissions, fuel)
- Product life cycle management (PLM)




Digital Twin Components



Digital Twin Implementation

- Combine:
 - HIL simulator (real time simulation, approved simulation models)
 - DT developer environment (Toolbox für DT tuning, AI, etc.)
- Data exchange via API
- Data archive in workstation

Developer Workstation




- DT-Tuning
- Machine Learning
- Analyzing algorithms
- Virtual sensors
- Digital image

Simulation System




- HIL real time simulator
- Hypersim Simulation Model
- Device controllers
- Logic Functions
- Analog Interfaces (Voltage, Current)
- Digital Interfaces


Aspects of Artificial Intelligence



Big Data
Analytics




Clustering




Non-linear
Optimization



Artificial
Neural
Networks




Forecast





What can AI do in Energy Systems?

Pattern recognition




- Find characteristic situations
- Identify system states
- Aggregate data
- Calculate characteristic indices



- Characteristic situations based on multidimensional input parameters


What can AI do in Energy Systems?

Anomaly detection




- Detect abnormal behaviour in
 - Load flows
 - Switching states
 - Information flow
- Intrusion detection
- Malfunctioning Assets

Forecast




- Time series forecast based on
 - Historic data
 - Current state parameters

Decision making





- Tree based trained decisions
- Automatic or assisting functionality
- Based on Expert knowledge and historical training data


AI for sub stations



- Immediate detection of
 - Malfunctioning assets
 - Corrupted data transfer
 - Abnormal system states




- System state identification
- Data aggregation
- Need for action?



- Go to autonomous mode?
- Take action in autonomous mode
- Fast autonomous action and notice to control center

AI implementation in sub stations



Digital twins and AI for Digital Substations


Digital Twins

- Detailed models of system
- Self tuning
- Anomaly detection by mismatch between model and real system
- Behavioral Forecast
- System state estimation

Artificial Intelligence


- Training based system model
- Anomaly and pattern detection and cause identification by training
- System state optimization
- System state forecast

- Subsidiary stand-alone system control
- Anticipatory system optimization
- Preprocessed data exchange with control center
- Robust system operation



DT and AI information exchange based on IEC 61850


Which data is to be exchanged (next to existing data exchange)? - A choice



Substation internal		
What	How	How often
Configuration of Field devices	Structured data	At data change
Models of Field devices	Complex data structures (e.g. XML-Style or JSON)	At data change



What	How	How often
System state parameters	Tables or XML-style	At data change
DT model parameters	Complex data structures (e.g. XML-Style or JSON)	At data change
Configuration data	Structured data	At data change





What	How	How often
Aggregated state parameters	Simple values	continuously
DT model parameters	Complex data structures (e.g. XML-Style or JSON)	At data change
AI Teaching parameters	Structured data	Initial and at major changes

DT and AI information exchange based on IEC 61850

Domain	What	How	How often	Usable IEC 61850 models
Station internal	Configuration of Field devices	Structured data	At data change	Standard LNs available (prop. Manufacturer data)
	Models of Field devices	Complex data structures (e.g. XML-Style or JSON)	At data change, mostly initial	Not really, maybe some SCL extension. Not the real scope of IEC 61850. Other models usable? CIM?
Station ↔ Station	System state parameters	Tables or XML-style	At data change	No models defined. Definition on state parameters necessary.
	DT model parameters	Complex data structures (e.g. XML-Style or JSON)	At data change	No models available. Scope of IEC 61850?
	Configuration data	Structured data	At data change	Standard LNs available (prop. Manufacturer data)
Station ↔ Control Center	Aggregated state parameters	Simple values	continuously	No models defined. Definition on state parameters necessary. Workarounds usable?
	DT model parameters	Complex data structures (e.g. XML-Style or JSON)	At data change	No models available. Scope of IEC 61850?
	AI Teaching parameters	Structured data	Initial and at major changes	No models available. Out of scope for IEC 61850? Filetransfer with proprietary data?

Some Lab results

System components Overview




HIL Simulator



Gefördert durch:
Bundesministerium
für Wirtschaft
und Energie
aufgrund eines Beschlusses
des Deutschen Bundestages

Station Model




Use Case 1: HVDC control, corrective Measures

Requirements


- Integration of HVDC links to AC networks
- In normal Operation: Setpoint for converters from control center
- In abnormal events, fast reaction and high dynamics necessary

Approach

- Precalculated Measures and events are sent to the station controller
- Station controller monitors measured values for pattern match
- Assigned measures are taken instantaneously
- Information to control center is sent




Use Case 1: HVDC control, corrective Measures



How to transmit patterns and measures in IEC 61850?

Name	Type	M/O/C
LNName	Inherited	M
...	Inherited	M
patternValues1	ERY	M
patternValues2	ERY	O (C1)
measIds1	VRV	M
measIds2	VRV	O (C1)
setPoints1	ERY	M
setPointIds1	VRV	M
setPoints2	ERY	O (C2)
setPointIds2	VRV	O (C2)
setPoints3	ERY	O (C3)
setPointIds3	VRV	O (C3)
... 4?		

Use Case 2: Resilient Intrusion Handling



Use Case 2a: Anomaly/Failure Detection

3 input parameters characteristics


- Anomalies caused by puckish Intrusion
- Unwanted manual disturbances
- System failures

Approach 1: Rule based Detection system

- Huge rule set necessary, high probability of loosing some events
- Based on ruleset reliable

Approach 2: AI-based pattern recognition

- Sufficient training data necessary
- Comprehensive detection of suspicious events
- Multi dimensional pattern analyses



Use Case 2a: Anomaly/Failure Detection

- Anomalies caused by puckish Intrusion
- Unwanted manual disturbances
- System failures

Approach 1: Rule based Detection system

- Huge rule set necessary,
high probability of losing some events
- Based on ruleset reliable

Approach 2: AI-based pattern recognition


- Sufficient training data necessary
- Comprehensive detection of suspicious events
- Multi dimensional pattern analyses

Data to be transferred

- Initial:
 - Knows pattern data (many tables/arrays)
 - Mainly complex voltage, current and frequency data
 - Known anomalies (and their causes)
- Continuously / on event:
 - Updated pattern data (tables/arrays)
 - Pattern corrections
 - Information on false positive detections

Current state

- Necessary data objects identified
- Only few of them transferrable according to standards
- Bottleneck: Lag of free configurable interface solution to HIL-simulator (IEC 61850)
- Current work:
 - Build some Interface for testing new IEC 61850 models with HIL simulator
 - Test other ways of complex data model transfer
 - Test DT and AI functionalities
- Test more use cases for DT application
- → 2 more project years to go



Conclusion

- DT and AI are powerful tools for handling increasing complexity of energy systems
- Supporting resilient system behaviour
- Makes decentralized computing power usable
- Challenges:
 - (Dynamic) System modeling in necessary depth
 - Getting/Generating teaching data
- Current data exchange mainly via proprietary data models → Need for standardized data models will be identified

Questions? Contact us!



ANDRÉ NAUMANN

Head of Energy Systems and Components

andre.naumann@iff.fraunhofer.de

