

Review

Microgrid Systems: Towards a Technical Performance Assessment Frame

Sophie Marchand ^{1,*}, Cristian Monsalve ², Thorsten Reimann ³, Wolfram Heckmann ³, Jakob Ungerland ¹, Hagen Lauer ⁴, Stephan Ruhe ² and Christoph Krauß ⁴

¹ Fraunhofer Institute for Solar Energy Systems ISE, Heidenhofstraße 2, 79110 Freiburg, Germany; jakob.ungerland@ise.fraunhofer.de

² Fraunhofer Institute of Optronics, System Technologies and Image Exploitation IOSB—Advanced System Technology Branch AST, Am Vogelherd 90, 98693 Ilmenau, Germany; cristian.monsalve@iosb-ast.fraunhofer.de (C.M.); stephan.ruhe@iosb-ast.fraunhofer.de (S.R.)

³ Fraunhofer Institute for Energy Economics and Energy System Technology IEE, Königstor 59, 34119 Kassel, Germany; thorsten.reimann@iee.fraunhofer.de (T.R.); wolfram.heckmann@iee.fraunhofer.de (W.H.)

⁴ Fraunhofer Institute for Secure Information Technology SIT, Rheinstraße 75, 64295 Darmstadt, Germany; hagen.lauer@sit.fraunhofer.de (H.L.); christoph.krauss@sit.fraunhofer.de (C.K.)

* Correspondence: sophie.marchand@ise.fraunhofer.de

Abstract: A microgrid is an independent power system that can be connected to the grid or operated in an islanded mode. This single grid entity is widely used for furthering access to energy and ensuring reliable energy supply. However, if islanded, microgrids do not benefit from the high inertia of the main grid and can be subject to high variations in terms of voltage and frequency, which challenge their stability. In addition, operability and interoperability requirements, standards as well as directives have addressed main concerns regarding a microgrid's reliability, use of distributed local resources and cybersecurity. Nevertheless, microgrid systems are quickly evolving through digitalization and have a large range of applications. Thus, a consensus over their testing must be further developed with the current technological development. Here, we describe existing technical requirements and assessment criteria for a microgrid's main functionalities to foster harmonization of functionality-level testing and an international conception of system-level one. This framework is proposed as a reference document for assessment frame development serving both microgrid research and implementation for a comprehensive understanding of technical microgrid performance and its current assessment challenges, such as lack of standardization and evolving technology.

Keywords: microgrid; assessment; performance metrics; reliability; distributed energy resources; cybersecurity



Citation: Marchand, S.; Monsalve, C.; Reimann, T.; Heckmann, W.; Ungerland, J.; Lauer, H.; Ruhe, S.; Krauß, C. Microgrid Systems: Towards a Technical Performance Assessment Frame. *Energies* **2021**, *14*, 2161. <https://doi.org/10.3390/en14082161>

Received: 9 March 2021

Accepted: 9 April 2021

Published: 13 April 2021

Publisher's Note: MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



Copyright: © 2021 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

Wildly seen as a key to support large-scale integration of renewable energy sources and low carbon technologies connected to low and medium voltage networks, microgrids (MGs) are expected to play a substantial role in reaching the UN's goal of "sustainable energy for all". They could be a building block of the centralized grid and foster the coupling of different energy sectors, facilitate demand-side management (DSM), or provide ancillary services, such as increased resilience or flexibility. Especially in Europe, MG technologies will support the recent clean energy legislation that requires creating electricity markets with "active customers/consumers and citizens" and "energy communities" [1–3].

However, internationally harmonized testing protocols and performance assessment guidelines for MG systems have yet to be defined. Challenging obstacles for a comprehensive MG performance assessment are fast evolving MG technologies, changing requirements for grid-connected and islanded operation, and a lack of standardization. Moreover, their associated performance levels and indicators are not commonly available.

Nevertheless, customers need to be able to compare MG controllers and functionalities on a neutral basis. The benchmarking of MGs functions would serve as a guideline for energy communities and industrial applications. Contributing to the effort of establishing standardized assessments of MGs, this paper describes the existing testing requirements and possible performance indicators for the following MG concerns: reliability, including the transition between operation modes, network protection, power quality and ancillary services, as well as energy dispatch and cybersecurity. However, the impact of outages by maintenance or faults on the system performance is not directly addressed in this paper. Those outages as also special flexibility aspects and self-healing capacities after faults are partly covered by the reliability aspects. Moreover, alternating current (AC) MGs are the main focus of this work as they can directly be integrated into existing power networks, making them a midterm growing market in developed economies and thus requiring a rapid standardization to ensure a coherent deployment.

The paper is organized as follows: Section 2 contextualizes MG testing by presenting its functionalities, standards, and existing testing architectures. Then, for each of those MG main concerns, Section 3 synthesizes the assessment requirements extracted from standards and from the literature as well as the associated performance measures. Finally, in Section 4, the testing challenges for each of these functions, along with possible MG assessment strategies to face them, are discussed.

2. Microgrid and Benchmarking

2.1. Microgrid Objectives and Functions

Different MG definitions have been set within the Institute of Electrical and Electronics Engineers (IEEE) 2030.7 standard [4], the US Department of Energy report [5], the International Electrotechnical Commission (IEC) 60050-617 standard [6] and the CIGRÉ MG evolution roadmap [1]. By aggregating them, an MG can be defined as a group of loads and generators that operates as a single entity in grid-connected or islanded mode concerning the utility grid, as illustrated by Figure 1.




Figure 1. General microgrid schematic illustrating the interconnected (switch closed) and islanded (switch opened) operation modes. POI—point of interconnection; LV—low voltage; MV—medium voltage.

As detailed in [1], MGs have three main objectives: to provide an alternative to local energy service in terms of power quality and/or reliability, to enhance the usage of local energy assets and to interface the main grid with variable local sources and loads. These objectives can have different priorities or required quality levels depending on the use case. Critical infrastructures may prioritize reliability in terms of continuity of supply and cybersecurity, energy communities may prioritize usage of local generation and energy dispatch, and MGs with sensitive industrial or information communication technology (ICT) loads may prioritize power quality. However, while implementing those features, MGs are challenging in terms of operation and control, which requires appropriate

standards and testing processes. Some of these challenges include stability issues, low inertia, bidirectional power flows and uncertainty [7,8].

2.2. Standards and Technical Specifications

Standards build a base of understanding the requirements of smart grids, including MG as a special kind of smart grid [9]. In particular, IEEE standards cover the interoperability and the interconnection of distributed resources with smart grids considering islanded microgrids (IMGs) and grid-connected microgrids (GMGs). Moreover, IEEE describes specific testing procedures for MG controllers and storage systems. Concerning IEC standard series 62898, it gives the requirements for the design and operation of MGs. Coming IEC publications will also tackle MG features, such as protecting MGs and its energy dispatch management. Those standards provide examples for MG structures, requirements and their control as well as protection in general that serve as recommendations, which are used and discussed later in this paper. Standards, grid codes and directives, as shown in Table 1, regulate the implementation and testing of MGs.

Table 1. Standards, grid codes and directives for delta-wye transformer (MG) systems.

Abbreviation	Title	Date of Issue
Standard		
IEEE 1547.4	IEEE Guide for Design, Operation, and Integration of Distributed Resource Island Systems with Electric Power Systems	07-2011
IEEE 2030	IEEE Guide for Smart Grid Interoperability of Energy Technology and Information Technology Operation with the Electric Power System (EPS), End-Use Applications, and Loads	09-2011
IEEE 2030.2	IEEE Guide for the Interoperability of Energy Storage Systems Integrated with the Electric Power Infrastructure	03-2015
IEEE 2030.3	IEEE Standard Test Procedures for Electric Energy Storage Equipment and Systems for Electric Power Systems Applications	06-2016
IEEE 2030.7	IEEE Standard for the Specification of Microgrid Controllers	12-2017
IEEE 2030.8	IEEE Standard for the Testing of Microgrid Controllers	06-2018
IEEE 2030.9	IEEE Recommended Practice for the Planning and Design of the Microgrid	03-2019
IEC 62898-1	Microgrids—Part 1: Guidelines for microgrid projects planning and specification	05-2017
IEC 62898-2	Microgrids—Part 2: Guidelines for operation	09-2018
IEC 62898-3-1	Microgrids—Part 3-1: Technical requirements—Protection and dynamic control	09-2020
IEC 62898-3-2	Microgrids—Part 3-2: Technical requirements—Energy management systems	Expected in 12-2022
IEC 62898-3-3	Microgrids—Part 3-3: Technical requirements—Self-regulation of dispatchable loads	Expected in 12-2021
DIN EN 50160	Voltage characteristics of electricity supplied by public electricity networks	11-2020
Grid codes for interoperability with the electrical power system/grid		
Commission Regulation (EU) 2016/631	Establishing a network code on requirements for grid connection of generators	04-2016
Directives		
Directive 2009/72/EC	Common rules for the internal market in electricity and repealing Directive 2003/54/EC	07-2019
FERC Order 888	The Federal Energy Regulatory Commission's Open Access Rule	1996
IT-SiG 2.0	Draft of a second law to promote the security of information technology systems (title translated from German)	05-2020
BSI-KritisV	Decree on the regulation of critical infrastructures according to the BSI-Act (title translated from German)	04-2016
NISRIR 7628	Guidelines for Smart Grid Cybersecurity	07-2014

The standards, grid codes and directives describe measures for testing the effectiveness of functionalities to ensure a necessary quality level. However, the customer or microgrid operator and the evolving microgrid market would benefit from additional information about the efficiency of functionalities as well. There are numerous descriptions of individual

MG systems and tests of single functionalities, but a generalized and harmonized view is missing.

2.3. Microgrid Test-Beds

Technical specifications, as described above, allow a standardized development of MGs, whose functionalities are tested through either simulation, hardware-in-the-loop systems or field experiments. To enable the comparison of those MG operations, benchmarking MGs have emerged from collaborations, such as the Consortium for Electric Reliability Technology Solutions (CERTS) or the CIGRÉ, as well as from specific field implementations. The overview of existing field experiments and test-beds given in Table 2 [10–12] underlines the variability of MG architectures and designs, which leads to challenges to establish a comparison framework for MGs. From the different existing MGs [1], this study focuses on MGs with one point of interconnection (POI). Table 2 summarizes a literature review on microgrid test-beds according to their application, power level and described tests. We notice that direct current (DC) MG systems are underrepresented compare to AC ones. Moreover, information about systems presenting recent activities and, thus, potential availability for further testing is given when available.

Table 2. MG systems and test-beds for MG with points of interconnection (POI) [10–12]. The information from the column “Specific Test” is extracted from the previous references. Acronyms: Centre for Renewable Energy Sources and Saving (CRES), Fraunhofer Institute for Energy Economics and Energy System Technology (IEE), Central Research Institute of Electric Power Industry (CRIEPI), and New Energy and Industrial Technology Development Organization (NEDO). Note that the sign “—” indicates that the information is not available for the considered site.

Application (Location)	Name (Organization)	Voltage Level	Rated Power (kW)	Specific Test	Site Available
Mixed, AC (Canada, Senneterre)	Boralex planned islanding (Hydro Quebec)	25 kV	8750	Transient response, outage solution	—
Test system, AC (US, Wisconsin—Madison)	UW microgrid (University of Wisconsin—Madison)	<1 kV	—	Investigation controls diesel generators	yes
Residential, AC (The Netherlands, Bronsbergen)	Bronsbergen Holiday Park (CONTINUON)	<1 kV	315	Central control	—
Residential, AC (US, Columbus, OH)	CERTS testbed (CERTS)	<1 kV	173	Power quality optimization and energy management	yes
Test microgrid, DC (Italy, —)	CESI RICERCA DER test microgrid (CESI)	<1 kV	251	Local and supervisory control with fast transients	yes
Residential, AC (Greece, Kythnos Island)	Kythnos island microgrid (CRES)	<1 kV	102	Islanded	yes
Residential and small business, AC (Germany, Kassel)	SysTec LV smart grid and MV hybrid system test bench (IEE)	<1 kV/20 kV	120/500	Islanding switches Local und supervisory control	—
Test system, AC (UK, Manchester)	Microgrid/flywheel energy storage laboratory prototype (University of Manchester)	<1 kV	42	Intelligent control	—
Test system, AC (Japan, Gunma)	Test network at Akagi (CRIEPI)	6.6 kV	1775	Algorithms for day-ahead planning	yes
Rural grid, AC (Japan, Kyotango)	Kyoto eco-energy project (NEDO)	MV	450	Internet-based communication for DER	—
Residential, AC (—)	CIGRE low voltage distribution benchmark system (CIGRE)	<1 kV	99	Control options for DER	—
Mixed loads, AC (—)	IEC microgrid benchmark (IEC)	25 kV	16,200	Setting of optimal protection systems	—

The diversity of MGs suggests that a universal MG architecture for benchmarking is not appropriate and that application-specific test systems must be developed. However, multiplication of testing processes has the risk of complexifying MG functionality assess-

ment and comparison. As a result, the balance between application-specific and general testing systems must be struck. Looking for suitable assessment requirements, we consider three main MG concerns: reliability, use of distributed local resources and cybersecurity.

3. Assessment Criteria for Microgrid Operation and Control

3.1. Microgrid Reliability

For the reliability of supply in an MG, we distinguish four main features: continuity of supply, power quality, safety and protection, and secure operation. For the latter, we focus on ancillary services. These features use partly overlapping functionalities. Thus, we sum up important assessment criteria in a common table at the end of this section after we describe them individually.

3.1.1. Continuity of Supply

Enhanced resilience and continuity of supply is an MG key feature in regions with frequent outages because of technical failures, weather events or insufficient capacity of the main grid. The islanded operation of the MG can provide a backup solution, and the efficiency of the transition process between grid-tied and islanded operation must meet the requirements of the supplied loads. This chapter addresses the assessment of this transition process whose assessment criteria are defined considering requirements, conditions and impacts of the transition between the different operation modes.

Four transition modes are defined: unplanned islanding, planned islanding, and black start and reconnect [4]. During the transition between grid-connected and islanded operation, fluctuations in voltage and frequency appear. For those fluctuations, different requirements exist mainly depending on the sensitivity of the supplied loads. An overview of different standards and guidelines is given in [13]. These standards and guidelines define classes for grids concerning their different compatibility levels to avoid damages at disturbances. Following the standards, class 2 correlates with the public grid, while class 1 is for sensitive loads with a high demand for power quality. Class 3 is for insensitive loads like in industrial grids. One requirement of MG control is to keep the disturbance level and the time duration within those defined limits. Especially in the case of unplanned islanding due to a fault or fault clearance in the main grid, for example, an MG can become unstable [14].

An abrupt difference between generation and load in conjunction with low remaining inertia may cause great deviations in frequency and voltage [15]. To ensure a smooth transition between grid-connected and island operation, different control strategies exist, such as the combination of bypass converter and switches or special controls [14,16–18]. For reconnection, the island interconnection device (IID) [19] shall check voltage, frequency and phase angle to ensure limitations are kept. [19] describes three reconnection modes, (1) active synchronization with a control mechanism to match voltage, frequency and phase angle at the POI, (2) passive synchronization, which reconnects when differences are within acceptable limits, and (3) de-energized reconnection (connection of the MG with all generators disconnected or turned off.).

To date, the standards do not contain any general criteria for an assessment of the transition between the modes. Ref. [20] recommends security and stability assessments of any transient processes of MGs in general. An assessment shall consider the addressed use-cases of the MG to bring the effect of disturbances for the operation of the MG into account. An MG for sensitive loads, such as controls or computer systems, needs a smoother transition than an MG for insensitive loads. A different criterion could be the time needed for a transition from steady-state modes grid-connected to islanded mode and vice versa and the duration and amount of unserved demand. A possible assessment matrix for this transition is proposed in Table 3. Here, the criteria for the transition assessment are fluctuations in voltage and frequency, their level of increase or decrease and how fast the steady-state is reached. The maximum rate of change of frequency (RoCoF) is a

further criterion, as well as the interruption in the supply of loads with load ratio and duration time.

Table 3. Microgrid assessment matrix for transition between grid-connected and island operation mode (example values for sensitive loads).

Fluctuations		Planned Islanding	Unplanned Islanding	Black Start	Resynchronization
Voltage	Level	$\leq \pm 3\%$	$\leq \pm 3\%$	$\leq \pm 3\%$	$\leq \pm 3\%$
	Duration time	≤ 1 s	≤ 1 s	≤ 1 s	≤ 1 s
Frequency	Level	$\leq \pm 1$ Hz	$\leq \pm 1$ Hz	$\leq \pm 1$ Hz	$\leq \pm 1$ Hz
	Duration time	≤ 1 s	≤ 1 s	≤ 1 s	≤ 1 s
	RoCoF	≤ 1 Hz/s	≤ 1 Hz/s	≤ 1 Hz/s	≤ 1 Hz/s
Interruption of supply	Load ratio	0%	0%	0%	0%
	Duration time	<20 ms	<20 ms	<20 ms	<20 ms

In the assessment, the four defined transition modes need to be considered. With the system average interruption duration index (SAIDI), the system average interruption frequency index (SAIFI) and the customer average interruption duration index (CAIDI) assessment indices for interruption of supply exist. These indices are commonly used in the energy sector, but the definition of the events used for the calculation is not fully harmonized [21] and should be adapted to MG use cases. Especially the exclusion of planned interruptions, interruptions shorter than three minutes and interruptions due to force majeure can contradict the reliability requirements for MGs. For grid planning, indices like “loss of load probability” or “expected energy not supplied” [22] are applied. In addition, other metrics were developed by user-driven organizations like the Information Technology Industry Council (ITI) [23] or the semiconductor industry [24].

3.1.2. Power Quality

The power quality in electrical grids plays an important role in ensuring a proper and secure operation of the electrical assets in the grid. The operation out of the limits specified in the national grid codes and international standards might raise different issues in electrical grids, such as lack of synchronization, resonance and outages, among others. Power quality becomes increasingly important in the MG, especially with the high penetration of renewable energy sources (RESs), where the availability of the resource follows a stochastic process. The presence of inverters and multiple control loops for balancing and stabilizing the MG cause a high introduction of harmonics and might lead to stability issues in the interaction of multiple control loops, as explained in [25]. Also, knowing the main grid status is a central requirement to control the MG safely. The requirements for power quality in public electrical grids are described in international standards and the grid codes. In Europe, the reference standard EN 50160 defines the essential requirements at the point of common coupling (PCC) under normal operation, which defines a minimal grid power quality for the customers. For instance, the requirements for different voltage levels are summarized in Table 4 [26]. For the continuity of supply and for the power quality parameters, additional industry-specific recommendations or standards exist for continuity of supply and power quality parameters.

To establish and implement countermeasures against power quality issues, a monitoring system comprised of multiple sensors and power quality analyzers distributed along the grid is recommended for a very detailed observation of the voltages and currents. These devices must be able to measure transient phenomena, short-duration events, long-duration events and steady-state. Table 5 summarizes the type of event and duration. The sampling rate and recording time must be adjusted in the measuring device depending on the type of event [27].

Table 4. Power quality requirements in DIN EN 50160 [26].

Parameter		Operational Range		
		Low Voltage	Medium Voltage	High Voltage
Frequency		49.5 Hz–50.5 Hz		
Voltage changes		$V_c \pm 10\%$		
Flicker		Long-term severity (Plt) ≤ 1		
Voltage	Dips	Up to 1000 per year (under 85% V_c)		No specified limit
	Interruptions	Some 10–50 per year (under 1% V_c)		
Overvoltage	Temporary	< 1.5 kV	< $1.7\text{--}2.0 \times V_c$	No specified limit
	Transient	Depends on the protection coordination system		
Asymmetry		(Ratio between negative and zero systems) < 2%		
Harmonic distortion		THD < 8%	THD < 5%	THD < 3%

Table 5. Type and duration of events in electrical grids.

Type of Phenomena	Phenomena/Event	Duration
Transient	Impulsive and oscillatory phenomena	Up to 16 cycles
Short duration	Dips, sags, swells and frequency variations	Typically, from 20 to 60 cycles
Long duration	Abnormal frequency and voltage variations. Power swings	Typically, in the range of minutes
Steady-state	Unbalanced voltages Harmonic content	Range of minutes to hours

The required amount of measuring devices and the allocation varies depending on the grid size and its topology. The measuring devices must be able to detect power quality issues within the entire grid and determine local areas where these issues are produced. Additionally, the measuring devices should be interconnected to a high availability communication system for the monitoring system. Despite the MGs' technical and environmental benefits, the existence of MGs in the electrical energy system creates many challenges in maintaining the power quality. Power quality problems, such as active-reactive power variation, voltage and frequency deviation, poor power factor, and unplanned blackouts, are common in MGs [28]. According to [29], the problem of power quality in MGs has three primary sources: the fluctuating of the generated power from the RES; the generated harmonics from the power electronic devices in the MG; the transition between the grid-connected and islanded mode during the MG operation. The existence of inverter-based generators (IBG) in the MG may reduce the quality of the supplied current to the load due to the generated harmonics from the switching process in the inverter. Moreover, connecting and disconnecting the MG from the main grid could lead to significant voltage and frequency variations, causing severe problems for the connected loads. Therefore, several studies have been conducted to improve the power quality of the MG in grid-connected and islanded mode by enhancing the design of the power-electronic inverters [30], enhancing the operation of the MG controller, or adding additional devices to the MG.

The MG controller's main objective is to maintain some power quality aspects by holding the voltage and frequency within the specified ranges under all operating conditions. In addition, the MG controller is responsible for managing the active-reactive power flow within the MG [31]. In this sense, the droop controller with different schemes has been widely used to coordinate the MG operation depending on the active and reactive power measurement, as well as the frequency and the voltage limitations. In [32], an adaptive virtual impedance control loop was proposed based on the droop controller concept to

guarantee an accurate distribution of the reactive power. In [33], the droop controller is utilized with a decentralized control scheme for nonlinear load sharing to improved voltage quality and reduces the MG overloading. A modified droop controller was introduced in [34] to improve load-sharing accuracy and operation stability. The conventional droop controller performance was improved by the dynamic decoupling of active and reactive power in the controlling mechanism.

Furthermore, due to the massive development in machine learning algorithms, many researchers utilized artificial intelligence algorithms to enhance the operation of the MG [35]. In [36], an artificial neural network-based controller is utilized to control the battery storage unit in an MG to enhance the power quality. Moreover, the k-nearest neighbor pattern recognition method is used to choose the proper compensator for improving the MG's power quality in [37]. Finally, additional components can be used to compensate for the power quality of MGs, such as solid-state transfer switch (SSTS), dynamic voltage restorer (DVR), distribution static compensator (DSTATCO), and unified power quality conditioner (UPQC) [37–39]. The performance of these devices can be improved by adding novel control algorithms. In [29], an online framework is proposed to calibrate the set point of the DSTATCOM by monitoring the point of common coupling of the MG and the distributed energy resource (DER) current. The referenced articles show the effectiveness of the specific monitoring and control approaches. However, a generalized approach for comparing their efficiency does not seem to be available.

3.1.3. Protection System

Changes in network structures are challenging for the protection system coordination. In the case of an MG, the changes in the network structures can be vast. While grid-connected, the main grid and all connected generators provide the fault current. In island mode, only the generators of the MG can provide the fault current. During island operation, the short circuit current level is usually significantly lower, especially in MG with a high share of IBG. Unlike synchronous machines, IBG can only provide a current close to their nominal currents under fault conditions. These circumstances lead to a change in the fault current level, and it gets close to the maximal operation current and, in some cases, to the change of the direction of the fault current. The resulting effect on network protection is very important and needs further studies for proper coordination. While island mode standards like [19] require accuracy of fault detection and clearance equal to the grid-connected mode, the traditional overcurrent protection devices become problematic in operation in these two modes. Indeed, especially with distributed IBG, [40–44] the fault current decreases and lead to longer tripping times (e.g., due to blinding effects) and unselective disconnection. For medium voltage (MV) MGs, [20] recommends using protection devices like the ones in the transmission system (e.g., current differential, distance protection). While for low voltage (LV) MGs using costly protection devices should not be necessary. This is why using fuses is very common in traditional LV networks. Common suggestions for MG protection are adaptive protection, additional protection devices, additional measurement points, directional protection devices, and using communication for protection devices [41–46], even if some devices need special adaptations [47]. Others [40] suggest using fault current limiters to keep unidirectional overcurrent relays with one single set of parameters for both the grid-connected and islanded mode. The purpose of the fault current limiters is to keep the fault current stable for all operation modes. With this, the protection should be capable of detecting faults selectively. These suggestions for protection schemes are divided into six categories [48]. In summary, the suggestions lead to two possible protection strategies: (i) decentralized (mostly time-grading-based) protection (e.g., [40]) and (ii) centralized (communication-based) protection (e.g., [49]). Both strategies should ensure fast and selective detection of faults for the different fault current levels of the operation modes and different generation and load conditions. Adaptive protection, as in [42,43], is a decentralized protection strategy with centralized coordination.

Compared to network protection, protecting a DER is relatively manageable [43]. There are only two possibilities for changes of the generators: (i) disabling or enabling of any anti-islanding protection and (ii) change of the control mode. Both do not affect the protection thresholds. Disabling or adapting the anti-islanding protection is necessary to avoid unintentional disconnection of generators in the case of switching from connected to islanded mode. For unintentional islanding, disabling or adapting the anti-islanding protection shall be faster than the anti-islanding protection itself to prevent a loss of generation. While changing from island mode to connected mode, the anti-islanding protection needs to be enabled or adapt according to the requirements for interconnection with the public grid. Fault ride-through (FRT) capability shall be provided in island operation to keep the voltage and the power provision during voltage sags and to provide the fault current to facilitate the detection of the fault by overcurrent relays. Especially for LV-connected IBG, using this capability is not very common. Some grid codes require a limitation of the FRT capability to stay connected without any provision of currents (VDE-AR-4105). Ref. [47] recommends adapting the FRT requirements for MGs by considering the response time of protection devices within the distribution level. The grounding system (i.e., the ground-fault protection) should be maintained for island operation as for grid-connected operation. Quite common is using a delta-wye transformer with grounded star point from MV to LV, while IBG uses a 3-phase connection. The change from a grounded system to an isolated system or a grounded system with isolated sources should be avoided [19]. Requirements from standards for units themselves must be considered as well. Overvoltage with values of phase-to-phase for phase-to-neutral structures may need to be considered for 1-phase to ground faults. This depends on the grounding system and the operation strategies of the MG.

Recommendations for MG protection schemes are given in [20] and the announced IEC TS 62898-3-1. The protection of an MG shall be reliable, rapid, sensitive and selective for both operation modes to ensure a safe and stable operation at any condition. Based on these technology-independent requirements, the assessment matrix for the reliability of the MG network protection may be used for grid-connected and island operation modes. Additionally, new devices and functions provide new potentials of failure, e.g., communication failure. The dependability of the MG protection compared to a protection system of a conventional network should also be considered for the assessment.

3.1.4. Reliable Operation with Focus on Ancillary Services

The secure operation essentially deals with the question of whether the power grid is operated in a stable state and remains stable even after failure events [22]. For this purpose, transmission system operators usually provide or procure ancillary services, although the provision by DER within MGs is getting more relevant in recent years. A grid-connected MG as a collection of controllable resources (dispatchable generators, energy storage system (ESS), adjustable loads) is considered capable of improving the reliability, security and efficiency of the interconnected grid [50,51]. In islanded mode, ancillary services must be adapted to the needs of the stable, stand-alone MG operation. The following paragraphs try to give an overview of ancillary services by showing selected examples from the literature where ancillary services were applied in MGs. In addition, different definitions of ancillary services are described, and a metric to evaluate the quality of ancillary services was created.

In [50], a microgrid controller that provides ancillary services to the utility grid was applied, whereas in [51], the focus is on the optimal planning of MGs, i.e., the optimal size and location of generators. Ref. [52] shows that the participation of more than one MG in the provision of ancillary services is useful. Subsequently, centralized control is compared with decentralized control. The main benefit of a centralized approach is the optimal economic operation, but technology and infrastructure for communication are required. Ref. [53–55] also concluded that a multi-agent system is the best structure to participate in the energy market. Ref. [56] implemented such an MG central controller to maximize the profit of the energy market participation. Ancillary services, in general, means “a service necessary for

the operation of a transmission or distribution system” [57]. A more detailed definition can be found in [58]: “Ancillary Services are all services required by the transmission or distribution system operator to enable them to maintain the integrity and stability of the transmission or distribution system as well as the power quality”. Ref. [58] also states the difference of system service and ancillary service: “System services are all services provided by some system function (such as a system operator or a grid/network operator) to users connected to the system. Ancillary services are services procured by a system functionality (system operator or grid/network operator) from system users to be able to provide system services.” It is important to mention that there is no uniform collection of all the ancillary services that can be provided. The European Directive 2009/72/EC [57] is the general framework for Europe, with Order 888 of the Federal Energy Regulatory Commission of the United States of America (FERC) as its counterpart. [59] presents an investigation of ten ancillary services with a focus on the provision from DER. It was determined that the provisioning of ancillary services by DERs could have a positive impact on power quality problems because of the following characteristics of a DER:

- Efficiency of local regulation with local sources [60];
- Fast response for harmonic compensation and network stability;
- Proximity to the user for backup supply and peak shaving;
- Reserve utility for other ancillary services when the utility has enough real power.

DER with a power electronic interface is capable of a very quick response to changes in the system, so it is very useful for the provision of ancillary services [61] whom the impacts are described in Table 6 [59].

Table 6. Ancillary services and their most beneficial impact [59].

Ancillary Services	Most Impact on	
	DER Owner	Grid
Voltage control	✓	✓
Frequency regulation	✓	✓
Load following	✓	
Spinning reserve		✓
Supplemental reserve (non-spinning)		✓
Backup supply	✓	
Harmonic compensation	✓	✓
Network stability		✓
Seamless transfer	✓	
Peak shaving	✓	
Congestion management		✓

3.1.5. Reliability Assessment Metrics

For the overall reliability, we distinguish between user and system requirements. Additionally, economic aspects should be considered for optimal operation. Table 7 [58,62–66] gives a survey of relevant functionalities where an assessment is needed.

Table 7. Overview of reliability assessment metrics [58,62–66]

	Metrics	Description
User requirements	Reliability	- Adequacy: system with sufficient facilities - Security: system responds to contingencies
	Power quality	- Operation of sensitive equipment is possible - Dealing with electrical phenomena (voltage sags, harmonics)
	Utilization	- Optimal utilization of resources
System requirements	Reliability	- Scheduling of generating units, transmission resources and transactions
	Stability	- System stability should be maintained
	Frequency control	- Frequency should stay within boundaries
	Voltage control	- Control of system voltage profile
	Load control	- Overloads should be prevented
	System restart	- System restart after a blackout
Economics	Cost of ancillary services	- Financial burden of the provider- Production and provision cost
	Price of ancillary services	- Procurer pays the provider
	End-user price of ancillary services	- Included in tariff of electricity - Final buyer and user of electricity

3.2. Use of Distributed Local Resources

Energy dispatch or energy management system (EMS) refers to the slowest MG control where operations are carried out at the minute scale or more. Furthermore, called tertiary control, this level consists of the operating and controlling features acting on the energy resources and loads to manage the power flow exchanges within the MG and with the main grid to ensure optimal operations [67]. This optimality is usually defined in terms of economic as well as ecological criteria. In charge of the energy dispatch optimization, EMS can be divided into different modules dealing with the demand and the production side as well as the forecasting of both [68]. Those modules are defined as:

- Demand-side management (DSM);
- Dispatch optimization (DO);
- Forecasting module (FM).

DSM includes methods used to adapt demand to available generation, for example, to promote self-consumption and reduce the aggregated energy consumption during peak demand [69]. These processes are encouraged by financial incentives, such as off-peak rates that lower the electricity cost during specific times as well as through consumer education. The aim of those preventive methods is not only to reduce the overall consumption but also to spread it temporally so as to match generation and infrastructure capacities with energy demand. By ensuring this energy balance, DSM reduces the need for investments in power system capacity. On the generation side, DO refers to the methods used to optimally generate energy and allocate it according to the loads, storage systems and sources [70].

The sources can be all kinds, including diesel generators, solar panels, or wind turbines. DO can aim for different optimization objectives, such as economical ones by reducing the energy costs or environmental by reducing the CO₂ emissions or by increasing the share of renewable energy used. Another optimization objective can be the power stability in the MG to ensure a high-power quality. Finally, FM refers to the forecasting techniques applied to predict power generation [71] as well as energy load [72] and electricity prices [73] based on external and internal factors. Forecasting techniques are numerous and can range from linear to nonlinear methods as well as machine learning ones. The techniques are selected according to the forecast requirements, the data available and the time resolution. Common forecasts for power generation are mainly related to renewable energy, such as solar and wind power.

Comparing EMS control features is challenging as various strategies, having distinct characteristics and objectives, have been developed to carry out those functionalities. To interpret the performance difference, it is necessary to identify the characteristics of the compared control modules. For example, the comparison of two energy load FMs having different time resolutions, prediction methods and data inputs will not allow concluding, which characteristics influence the variations of performance on the MG fuel consumption. Additionally, comparing DSM modules presenting distinct control architectures and prediction horizons will also lead to a weak interpretation of their performance differences as their source is uncertain. Moreover, to evaluate tertiary control modules, it is recommended to identify and limit their characteristics differences.

This identification can be based on Table 8 [68–83], which presents a comprehensive synthesis of those characteristics from the literature. Furthermore, the comparison interpretation relies on performance metrics used. The metrics should be defined according to the application objectives and constraints as well as the features compared. Indeed, adequate performance indicators are necessary to support the interpretation and the selection of the feature strategy. For example, comparing two DO modules in terms of renewable energy penetration may not give a complete performance representation if the application is limited in terms of computational resources. To identify the metric or set of metrics to consider Table 9 [71,72,74,75,77,78,80,81,84–89] proposes an extensive combination of them. Finally, recommendations to compare EMS control features of MG include the evaluation and limitation of distinct characteristics between the compared modules as well as the selection of representative sets of metrics in terms of the study objectives and constraints.

Table 8. Characteristics of energy management system (EMS) [68–83].

	Characteristics	Description
Definition	Objective and constraints	Goals of the process defined in terms of statement, objective function or/and conditions to satisfy
	Method	Identification of the process methodology
	Prediction horizon	How far the process operation is planned in the future
	Temporal resolution	Discrete resolution of the process operation concerning the time
	Application scope	Range of applications covered by the process operation (e.g., capacity to include flexible energy sources, application scale, climates considered, microgrid operations and coordination . . .)
	Control architecture (not applicable for FM)	Repartition of the control tasks and coordination between subsystem
	Control adaptability (not applicable for FM)	Capacity of the control system to be flexible toward control strategy changes
	Uncertainty modeling	Capacity to include uncertainty within the process forecast
	Failure handling	Process procedures to cope with failures
	Scalability	Capacity of the process to be easily expanded in terms of application scope
Source	Input variables	Description of the data transferred to the process to perform its operation
	Preprocessing	Description of the preliminary data transformations performed before transferred to the process
	Communication type	Communication needs with the process in terms of data size exchanged, data frequency exchange, addressability entities and infrastructures
Global	Market interaction	Possibility to incorporate energy contract or to directly integrate energy market inputs into the process
	Security and privacy	Confidentiality and protection of data exchange in the overall energy system during the process operation
	Legal feasibility	Need of new or modified laws to implement the process strategy

Table 9. Metrics synthesis of EMS control features [71,72,74,75,77,78,80,81,84–89].

	Metrics	Description
Economic	Consumption cost	Cost associated with the energy consumption usually given in currency by time or in leveled cost of energy
	Implementation cost	Economic impact of the process implementation on consumer and/or utilities
	Energy imported	Amount of energy imported from the grid during a given period (if a microgrid is grid-connected)
Energy efficiency & Environment	Peak load occurrence	Energy consumption event going above a given threshold, generally given as a number of occurrences
	Load factor	Ratio of the average load over the maximum load within a given time period
	Power loss	Energy losses due to the high resistance at the grid connection and the voltage fluctuation expressed in power units
	Temporal impact	Temporal effect of the process operation on the energy efficiency
	Fuel consumption	Amount of fuel consumed by the microgrid during a given period
	Renewable energy penetration	Percentage of the energy demand cover by renewable energy during a given time
Process	Maturity	Stage of technology development used for the process
	Responsiveness	Duration between the observation of a change in the system and the reaction of the process
	Resilience	Process capability to recover to stable system operation or adjust to changes
	Availability	Degree to which the process is in a specific state
	Computational resources	Time and energy required by the process operation
	Accuracy	Difference between the optimal and theoretical outcome of the process
	Uncertainty	Uncertainty measure of the process operation
	Ramps characterization	Fluctuation measure of the process operation
Infrastructure	Ease of integration	Process integration ability into the existing system
	Maintainability	Ease of the process maintenance
	Import violation	Importations that are outside the thresholds required by the utility grid in terms of time, energy and peak power
User	Acceptance	Engagement of the user with the process operation
	Customer experiencing no interruptions	Percentage of microgrid customers experiencing no interruption from the energy supply
	Load curtailed	Unplanned removal or reduction of load requirements
	Social welfare	Measure of the efficient energy consumption achieved among several users whom the utility is aggregated
	Operational transparency	Extend to which a human operator can interact with the process

3.3. Cybersecurity

Cybersecurity is an important factor in the life cycle and operation of an MG. This section gives an overview of cybersecurity aspects as well as current approaches for improving security on different levels. Subsequently, a summary of quality benchmarks for a cyber-secure MG is presented, along with recommended actions, which can reduce security risks in such systems.

The MG is a cyber-physical system, which comprises information, control, communication and field levels [90]. The information level refers to the processing, storing, and

provisioning of information in data centers and cloud applications. The aggregated information is also used at the control level, which coordinates the secure, reliable and stable operation of the grid. Control-level applications (e.g., SCADA and DCS) are concerned with monitoring and managing grid operations. The communication level comprises information and ICT, which allows the timely and secure transmission of information between different actors (e.g., measurements or control commands). Lastly, the field level includes the electrical equipment and smart devices involved in energy generation, transmission, distribution, consumption, and measurement.

Attacks targeting an MG can be initially classified as passive and active. Passive attacks extract valuable information, such as consumer data, credentials, and configurations. Information leakage is generally a high-risk problem if privacy is a concern, but it appears at first inconsequential for the grid's safe operation. However, the leaked information could allow passive actors to corrupt a system actively in the future [91]. Active attacks include injection of meter readings, forging or replaying commands, and elevating the privilege of users to corrupt a system temporarily (e.g., to disrupt or destroy it) or permanently (i.e., as a strategic access point in the future). Adversaries can exploit several attack vectors, which introduce significant risks in the electrical infrastructure. In a worst-case scenario, attacks can lead to blackouts, physical damage, and loss of life. Exploitable attack vectors must be addressed on a device, software, communication, and orchestration level [92].

The main cyber-security challenge on a field or device level can be summarized as the reliance on inputs and actions of devices that may be in the hands of an adversary. Indeed, the issue is compounded by the fast deployment of smart devices without adequate security and protection. Trust in the MG control and operation can be defined as some degree of confidence that, during some specific interval, the appropriate actor is accessing accurate and unmodified data, which is created by the intended device in the expected location at the proper time and communicated using the expected protocols [93]. Traditionally, the grid's control system is viewed as an environment with implicit security and trust (e.g., because the infrastructure is owned, operated, and protected by the operator). However, MG devices do not necessarily have physical protection and are owned and operated by multiple parties, including potential adversaries. Devices must be designed to be tamper-resistant to prevent physical manipulation. Additionally, the push towards cloud services for grid management has significantly increased the number and variety of devices and parties involved such that often, access control-based policies will not be applicable or scale well [94]. The use of trusted computing hardware for MG devices can effectively address the need for adequate authentication, authorization, and credential protection as they offer a secure foundation (a root of trust) for important security guarantees, such as integrity, authenticity, confidentiality, provenance, and resilience [95–97].

The complexity of software systems, which enable the function, control, and processing in a smart MG, is increasing and rivals that of today's commodity systems (e.g., IoT devices, mobile and desktop computers) [98]. MG layers commonly share software from other domains and computing systems and with it their bugs and vulnerabilities. However, threats related to software engineering are well known and can be addressed in several ways [99]. The software systems in an MG will have to be designed and tested to the same principles as software, which is expected to be secure. Safety-critical systems often must undergo much more rigorous testing and certification procedure. One approach to improve software quality is referred to as formal specification and verification. However, large pieces of software (e.g., legacy code, updates, or patches) are notoriously laborious to specify, verify, or certify [100]. Fuzzing technologies provide an efficient way for testing such software systems for bugs and errors [101]. The MG is an essential infrastructure where non-critical software (e.g., user interfaces) should not interfere with critical software components. Applications from different security domains and with different levels of criticality must be isolated from another.

Smart MG devices use general-purpose internet technologies [93], whereas traditional grid communications have relied on reliable, predictable, and contained communication

channels for monitoring and control. Compared to transmission and distribution grids, the lack of standardization for secure and reliable communication for MG systems poses risks in terms of cybersecurity [90] as described in Table 10. This threat can be reduced by adopting open standards communication protocols (e.g., DNP3, IEC61850), which promote standardization and security as the associated cybersecurity framework developed for them is accessible to every actor. However, standardization in the communication systems also has to include different levels of the open systems interconnection infrastructure in electrical systems as recommended by IEC 62351 [102]. The use of appropriate and secure communication protocols (e.g., TLS, IPsec) is mandatory when actors communicate over public networks to ensure properties such as confidentiality, integrity, privacy, and non-repudiation. In summary, an MG network security concept should include frameworks for authentication, authorization, and encryption if necessary [93,103]. An intrusion detection system (IDS) can be effective at detecting adversaries on the network and directing mitigation procedures [91].

Table 10. Common weaknesses and remedies for microgrid security [90].

Domain	Risks	Mitigation
Software application and security	Poor code quality	- Considering best practices principles - Precise specification for safety-critical software - Testing strategies for different kinds of software - Appropriate soft- and hardware architectures for mixed-criticality environments
	Inadequate configuration management	
	Poor permissions and access management	
	Inadequate patch management	
	Inadequate data integrity checking	
	Inadequate error handling	
Communication and privacy	Inadequate database protection	- Implementation of IDS with mixed approaches - Standard communication protocols - End-to-end-encryption paired with strong authentication - Implementation of privacy policies using privacy-preserving technologies
	Inadequate segregation and segmentation	
	Inadequate access control	
	Weak intrusion detection and prevention	
	Weak encryption mechanism	
	Inadequate sensitive data protection	
Field devices and resiliency	Inadequate network monitoring and auditing	- Tamper-proof hardware design - Trusted platforms for accessing information with adequate authentication, authorization and credential protection - Identification of cyber-attacks and their risks - Protect assets at all times - Prevent attacks by following security guidelines and standards - Define and implement a recovery strategy
	Inadequate anomaly tracking	
	Unprotected physical access	
	Improper device configuration	
	Inadequate firmware protection	
	Lack of tamper-resistance hardware	
	Weak authentication and authorization	

Today, a signature or rule-based IDS can be augmented with statistical methods [104,105], knowledge-based, and machine-learning methods [104] to detect a greater variety of attacks and anomalies [92].

Lastly, cyber-resiliency contributes significantly to power availability [106]. Service must remain available as much as possible even in the face of adverse conditions [107,108]. In case of faults, a resilient system must have an alternative way to continue its operation and, eventually, recover and return to the intended mode of operation. While the use of cloud systems generally improves the cyber-resiliency of a larger system, they do not cover smart devices and endpoints of an MG. Faults, which render a device or service

unavailable, can be introduced by various IT attacks [109]. An MG system should implement an “identify, protect, detect, respond, and recover” cycle as proposed in the NIST Cyber-framework [110]. Systems need to be prepared for successful cyberattacks with requirements for availability, vital services, and playbooks for recovery [111]. Attacks should be prevented and assets protected by following relevant security standards. Responding to a cyber-incident requires detection and alert generation, but also decision-making. Lastly, MG devices should include a predetermined and secure way to recover from a cyberattack and return to a secure state [112–114].

Historically, privacy has not been a concern in the electrical grid [115]. However, the information that is available in a smart MG allows deep insights: usage data alone reveal whether someone is at home, work, or traveling or whether certain facilities are busy. Several records are sensitive [110]: name, address, account, meter reading, bills, billing history, home area appliances, lifestyle, DERs, meter IP, service provider—this list will likely be extended as new energy markets emerge. Privacy-preserving technologies will be mandatory and include privacy policy-based access to and usage of data, homomorphic data encryption [116], as well as privacy-focused market solutions [117].

4. Discussion

The following section discusses challenges concerning each previously introduced aspect of an MG assessment as well as further system-level considerations.

Starting with the transition between modes of operation, evolving technical matters are making testing protocols quickly obsolete, requiring changing recommendations. In particular, the control of voltage and frequency during transient events, including the coupling of active and reactive power for the voltage control, are still research topics. The issue is compounded by the increasing insertion of volatile DERs, which must operate within narrow set-point boundaries due to the low inertia of the system. In addition, quasi-static state and state transition in an MG are difficult to condition to assess given that they require technical stabilization that must also be included and tested. Lastly, assessment indices that quantify the interruption of supply are still to be adapted into a key performance index for such MG transition events.

Depending primarily on MG operation modes, power quality is also highly affected by the amount of power electronic devices within the MG. Furthermore, adaptive control strategies, which coordinate different grid elements, need to be implemented to compensate for these two factors. The control strategies are already technically challenging due to, for example, the insertion of a DER, and yet their complexity is increasing, and so are the requirements testing them. This aspect underlines that assessment processes need to evolve with technological advancements to encompass novel functionality and enable comprehensive but feasible testing protocols.

Concerning protection systems, their design is one of the main challenges in MG operations [45,46] as it relies on the network structure, changes in generation and load situation, which leads to various individual requirements. These specificities are reinforced by the need to identify efficient protection strategies ensuring the safe operation of different MG modes with very different fault current levels and directions as well as possible changes in the grounding system. That is why the establishment of an MG taxonomy is needed to generate group-specific performance indices, which facilitates standardized assessments.

Finally, further aspects of protection systems that could not be treated here in detail should also be considered in MG testing: coordination with the protection system of the main grid, while grid-connected, detection of unintentional islands within the MG during island operation and the cost efficiency of MG protection strategies [84].

Regarding ancillary services, there are two main obstacles for an assessment of the provision of ancillary services: one issue is the lack of a common understanding of ancillary services, which also undermines trade across borders [58]. Furthermore, the provision of ancillary services by DERs is not common in competitive markets, and guidelines are often not harmonized and can even contradict themselves [54,118]. Those aspects show that

international institutions are necessary to harmonize the definitions and requirements for ancillary services to optimize exchanges and overall grid quality. Again, an assessment procedure should consider the change in requirements for grid-connected and islanded modes.

To develop EMS benchmarking processes for an MG, we observe several challenges within the literature, such as the testing representativeness. [76] proposes that evaluation scenarios should be defined by using aggregated time-series, such as household load profiles, to reduce the dependency of the performance results on a given dataset. However, this aspect could be challenging in the MG context since EMS are usually applied locally where high variability of the measured data are observed. This raises questions regarding a suitable environment for EMS testing. Most of the literature offers EMS evaluation from simulation software whose representativeness is uncertain or useful only for a specific MG implementation [119] with limited reproducibility. Nevertheless, a growing number of publications are using Control-Hardware-in-the-loop frameworks [89] to evaluate MG control as recommended by [120], which makes this framework a suitable candidate for further EMS benchmarking developments. In addition to the testing environment, considerations are also made on the representativeness of an independent evaluation of EMS strategies without the primary level control simulation [121]. Finally, concerning evaluation metrics, beyond economic and ecological ones, control robustness, adaptivity [7] and user acceptance [86] are underlined as essential features, which testing should include.

Growing with MG digitalization, the main cybersecurity challenges in MGs can be summarized as follows: (i) many parties rely on a large number of smart devices that may be in the hands of an adversary and (ii) a general lack of security standards for devices, software, configuration, communication, and orchestration. While solutions, which promote trust and authentication from field devices to cloud services [95–97] are available and can be benchmarked, such solutions still need to scale properly and be efficient to be useful in smart grids and MGs. Another challenge lies in the assessment and testing of trust management for particularly constrained or legacy devices that may not be able to implement recommended solutions. Furthermore, cyber-resilience is essential in MG designs, as faults and attacks must not be allowed to propagate, and the system, as a whole, needs a sure way to securely recover from an adverse or emergency situation. Lastly, aside from general references, there are no supporting security standards, which promote or evaluate a cyber-resilient design, implementation or operation of an MG yet.

Finally, MG system-level assessment gaps have also been identified in the literature, such as the difference between alternating current or direct current grid testing directives and the growing implementation of hybrid grids [122]. Moreover, we note that MGs' general requirements and their interconnection to the main grid were discussed in MG research projects but not yet implemented in standards or grid codes. Furthermore, such standards will face difficulties due to the various applications of MG that make their requirements often implementation-specific. Finally, we observe a rise in the importance of privacy as more information is shared for operational and economic reasons. Especially energy producer and consumer information is an important asset that needs to be protected appropriately; yet, the requirements are still vague and varied. In addition, we can certainly conclude that a lack of privacy considerations can harm the proliferation of energy exchange markets and lead to a loss of customer acceptance and trust.

5. Conclusions

Due to their ability to connect to the main grid and their ongoing digitalization, MG systems should implement several functionalities, such as transition mode capability, power quality, protection systems, ancillary services, energy management and cybersecurity. Despite existing or evolving standards and directives for specific MG functions, they are not yet available to MGs' overall important aspects. Further, system-level MG benchmarking remains to be defined, and functionality-level benchmarking must be clarified. There is no consensus in the literature in terms of performance indicators and requirements extracted

from the standards. To improve this situation, we presented and summarized the following topics:

- MG main functionalities and associated standards as well as existing system-level MG architectures used for testing;
- Actual requirements and assessment criteria for reliability, use of distributed local resources and cybersecurity within MG;
- Prospects for the evolution of functionality and system-level MG testing as well as their current limitation.

This study can serve as a reference to start benchmarking activities at the MG functionality level but also at its system level. Indeed, we hope that this paper will contribute to a call for more and better standardization at the MG system level with internationally defined MG architectures for testing such that benchmarking is possible.

Author Contributions: Conceptualization, S.M. and W.H.; microgrid and benchmarking, S.M. and W.H.; microgrid reliability, C.M., T.R., W.H., J.U. and S.R.; use of distributed local resources, S.M.; cybersecurity, H.L., C.M. and C.K.; discussion, all authors; writing—original draft preparation, all authors.; review and editing, S.M.; supervision, S.M. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Data Availability Statement: Data sharing not applicable.

Acknowledgments: This work was supported by the Fraunhofer Cluster of Excellence Integrated Energy Systems (CINES) that supports the Fraunhofer Microgrid Benchmarking Initiative, which seeks to develop testing facilities for low and medium voltage MGs connecting several institutes laboratories.

Conflicts of Interest: The authors declare no conflict of interest.

Abbreviations

AC	Alternating current
CAIDI	Customer average interruption duration index
DC	Direct current
DER	Distributed energy resource
DO	Dispatch optimization
DSM	Demand-side management
DSTATCOM	Distribution static compensator
DVR	Dynamic voltage restorer
EMS	Energy management system
ESS	Energy storage system
FM	Forecasting module
FRT	Fault ride through
GMG	Grid-connected microgrid
IBG	Inverter-based generation
ICT	Information communication technology
IID	Island interconnection device
IDS	Intrusion detection system
IEC	International Electrotechnical Commission
IEEE	Institute of electrical and electronics engineers
IMG	Islanded microgrid
LV	Low voltage
MG	Microgrid
MV	Medium voltage
POI	Point of interconnection

SAIDI	System average interruption duration index
SAIFI	System average interruption frequency index
SSTS	Solid-state transfer switch
UPQC	Unified power quality conditioner
RES	Renewable energy source
RoCoF	Rate of change of frequency

References

- Marnay, C.; Chatzivasileiadis, S.; Abbey, C.; Iravani, R.; Joos, G.; Lombardi, P.; Mancarella, P.; von Appen, J. Microgrid Evolution Roadmap. In Proceedings of the Smart Electric Distribution Systems and Technologies (EDST), 2015 International Symposium on IEEE, Vienna, Austria, 8–11 September 2015; pp. 139–144.
- Oleinikova, I.; Hillberg, E. Micro vs MEGA: Trends Influencing the Development of the Power System. May 2020. Available online: https://ntnuopen.ntnu.no/ntnu-xmlui/bitstream/handle/11250/2678100/ISGAN_DiscussionPaper_Annex6_microVsMEGA_2020.pdf?sequence=1 (accessed on 1 March 2021).
- Aceby, S.; Tjäder, J.; Bastholm, C. The role and interaction of microgrids and centralized grids in developing modern power systems. Cigrée Electricity Supply to Africa and Developing Economies: Challenges and Opportunities. In Proceedings of the 8th Southern Africa Regional Conference, Cape Town, South Africa, 14–17 November 2017.
- IEEE 2030.7-2017. *IEEE Standard for the Specification of Microgrid Controllers*; IEEE Std: Piscataway, NJ, USA, 2018.
- U.S. Department of Energy, Office of Electricity Delivery and Energy Reliability Smart Grid R&D Program. *DOE Microgrid Workshop Report*; U.S. Department of Energy: Washington, DC, USA, 2011; pp. 1–32.
- 60050-617. Amendment 2—International Electrotechnical Vocabulary (IEV)—Part 617: Organization/Market of Electricity. 2017. Volume 01.040.29. Available online: <https://webstore.iec.ch/publication/27437> (accessed on 1 March 2021).
- Olivares, D.E.; Mehrizi-Sani, A.; Etemadi, A.H.; Cañizares, C.A.; Iravani, R.; Kazerani, M.; Hajimiragha, A.H.; Gomis-Bellmunt, O.; Saeedifard, M.; Palma-Behnke, R.; et al. Trends in microgrid control. *IEEE Trans. Smart Grid* **2014**, *5*, 1905–1919. [\[CrossRef\]](#)
- Soshinskaya, M.; Crijns-Graus, W.H.J.; Guerrero, J.M.; Vasquez, J.C. Microgrids: Experiences, barriers and success factors. *Renew. Sustain. Energy Rev.* **2014**, *40*, 659–672. [\[CrossRef\]](#)
- Basso, T.; Hambrick, J.; DeBlasio, D. Update and review of IEEE P2030 Smart Grid Interoperability and IEEE 1547 interconnection standards. In Proceedings of the Innovative Smart Grid Technologies (ISGT), Washington, DC, USA, 16–20 January 2012; pp. 1–7.
- Papathanassiou, S.; Hatziargyriou, N.; Strunz, K. A benchmark low voltage microgrid network; Technol. impacts Dev. Oper. Performances. In Proceedings of the CIGRE Symposium: Power Systems with Dispersed Generation, Athens, Greece, 13–16 April 2005; pp. 1–8.
- Lidula, N.W.A.; Rajapakse, A.D. Microgrids research: A review of experimental microgrids and test systems. *Renew. Sustain. Energy Rev.* **2011**, *15*, 186–202. [\[CrossRef\]](#)
- Naily, N.E.; Saad, S.M.; El Misslati, M.M.; Mohamed, F.A. Optimal Protection Coordination for IEC Microgrid Benchmark Using Water Cycle Algorithm. In Proceedings of the 10th International Renewable Energy Congress (IREC), Sousse, Tunisia, 26–28 March 2019; pp. 1–6.
- Kannan, A.; Reimann, T.; Strauss-Mincu, D.; Rolle, M.; Dresel, C. Ensuring power quality and stability in industrial and medium voltage public grids. In Proceedings of the 19th International Scientific Conference on Electric Power Engineering (EPE), Brno, Czech Republic, 16–18 May 2018; pp. 1–6.
- Cagnano, A.; de Tuglie, E.; Rasolomampionona, D.D.; Klos, M.; Favuzza, S.; Massaro, F.; Zizzo, G. Transitions from grid-connected to island operation of Smart Microgrids. In Proceedings of the 2019 IEEE International Conference on Environment and Electrical Engineering and 2019 IEEE Industrial and Commercial Power Systems Europe (EEEIC / I&CPS Europe), Genova, Italy, 10–14 June 2019; pp. 1–6.
- Farrokhhabadi, M.; Canizares, C.A.; Simpson-Porco, J.W.; Nasr, E.; Fan, L.; Mendoza-Araya, P.A.; Tonkoski, R.; Tamrakar, U.; Hatziargyriou, N.; Lagos, D.; et al. Microgrid Stability Definitions, Analysis, and Examples. *IEEE Trans. Power Syst.* **2020**, *35*, 13–29. [\[CrossRef\]](#)
- Das, D.; Gurralla, G.; Shenoy, U.J. Transition between grid-connected mode and islanded mode in VSI-fed microgrids. *Sādhanā* **2017**, *42*, 1239–1250. [\[CrossRef\]](#)
- Lissandron, S.; Mattavelli, P. A controller for the smooth transition from grid-connected to autonomous operation mode. In Proceedings of the 2014 IEEE Energy Conversion Congress and Exposition (ECCE), Pittsburgh, PA, USA, 14–18 September 2014; pp. 4298–4305.
- Trinh, Q.N.; Wang, P.; Choo, F.H.; Jin, C.; Pan, X.; Lee, H.H. A novel control strategy for smooth transition between stand-alone and grid-connected operations of distributed generation. In Proceedings of the 2015 9th International Conference on Power Electronics and ECCE Asia (ICPE-ECCE Asia), Busan, Korea, 27–30 May 2015; pp. 1276–1281.
- IEEE 1547. 4-2011. *IEEE Guide for Design, Operation, and Integration of Distributed Resource Island Systems with Electric Power Systems*; IEEE Std: Piscataway, NJ, USA, 2011.
- IEEE 2030. 9-2019. *IEEE Recommended Practice for the Planning and Design of the Microgrid*; IEEE Std: Piscataway, NJ, USA, 2019.
- CEER. *6th CEER Benchmarking Report on the Quality of Electricity and Gas Supply—2016*; CEER: Brussels, Belgium, 2016.

22. BMWi, r2b energy consulting GmbH, Consentec GmbH, Fraunhofer ISI, TEP Energy GmbH. *Definition and Monitoring of Security of Supply on the European Electricity Markets*; Federal Ministry for Economic Affairs and Energy (BMWi): Berlin, Germany, 2019.
23. ITIC. *ITI (CBEMA) Curve Application Note*; Information Technology Industry Council (ITIC): Washington DC, USA, 2019.
24. SEMI F47. *SEMI F47-0706 (Reapproved 0812)—Specification for Semiconductor Processing Equipment Voltage Sag Immunity*; SEMI: Milpitas, CA, USA, 2012.
25. Yang, S.; Ruhe, S.; Schaller, F.; Nicolai, S.; Bretschneider, P. Dynamic Simulation of Low-voltage Distribution Grid with Integration of Power Electronics coupled Loads and Generators. In *Proceedings of the 53rd International Universities Power Engineering Conference (UPEC)*, Glasgow, Scotland, 4–7 September 2018; pp. 1–5.
26. DIN EN. 50160. *Voltage Characteristics of Electricity Supplied by Public Distribution Networks*; GERMAN Version EN 50160:2010 + Cor.:2010; Beuth Verlag GmbH: Berlin, Germany, 2011.
27. Dwivedi, S.K.; Jain, S.; Gupta, K.K.; Chaturvedi, P. *Modeling and Control of Power Electronics Converter System for Power Quality Improvements*; Academic Press, Elsevier: London, UK, 2018; ISBN 978-0-12-814568-5.
28. Vinayagam, A.; Swarna, K.S.V.; Khoo, S.Y.; Stojcevski, A. Power Quality Analysis in Microgrid: An Experimental Approach. *J. Power Energy Eng.* **2006**, *4*, 17–34. [[CrossRef](#)]
29. Bagheri, M.; Nurmanova, V.; Abedinia, O.; Salay Naderi, M. Enhancing Power Quality in Microgrids With a New Online Control Strategy for DSTATCOM Using Reinforcement Learning Algorithm. *IEEE Access* **2018**, *6*, 38986–38996. [[CrossRef](#)]
30. Pavan Kumar, Y.V.; Ravikumar, B. A simple modular multilevel inverter topology for the power quality improvement in renewable energy based green building microgrids. *Electr. Power Syst. Res.* **2016**, *140*, 147–161. [[CrossRef](#)]
31. Alramlawi, M.; Mohagheghi, E.; Li, P. Predictive active-reactive optimal power dispatch in PV-battery-diesel microgrid considering reactive power and battery lifetime costs. *Sol. Energy* **2019**, *193*, 529–544. [[CrossRef](#)]
32. Dong, H.; Yuan, S.; Han, Z.; Ding, X.; Ma, S.; Han, X. A Comprehensive Strategy for Power Quality Improvement of Multi-Inverter-Based Microgrid With Mixed Loads. *IEEE Access* **2018**, *6*, 30903–30916. [[CrossRef](#)]
33. Yazdavar, A.H.; Azzouz, M.A.; El-Saadany, E.F. A Novel Decentralized Control Scheme for Enhanced Nonlinear Load Sharing and Power Quality in Islanded Microgrids. *IEEE Trans. Smart Grid* **2019**, *10*, 29–39. [[CrossRef](#)]
34. Bouzid, A.E.M.; Sicard, P.; Chaoui, H.; Cheriti, A.; Sechilariu, M.; Guerrero, J.M. A novel Decoupled Trigonometric Saturated droop controller for power sharing in islanded low-voltage microgrids. *Electr. Power Syst. Res.* **2019**, *168*, 146–161. [[CrossRef](#)]
35. Kow, K.W.; Wong, Y.W.; Rajkumar, R.K.; Rajkumar, R.K. A review on performance of artificial intelligence and conventional method in mitigating PV grid-tied related power quality events. *Renew. Sustain. Energy Rev.* **2016**, *56*, 334–346. [[CrossRef](#)]
36. Alshehri, J.; Khalid, M. Power Quality Improvement in Microgrids Under Critical Disturbances Using an Intelligent Decoupled Control Strategy Based on Battery Energy Storage System. *IEEE Access* **2019**, *7*, 147314–147326. [[CrossRef](#)]
37. Moreira, A.C.; Paredes, H.K.M.; de Souza, W.A.; Marafao, F.P.; da Silva, L.C.P. Intelligent Expert System for Power Quality Improvement Under Distorted and Unbalanced Conditions in Three-Phase AC Microgrids. *IEEE Trans. Smart Grid* **2018**, *9*, 6951–6960. [[CrossRef](#)]
38. Ansari, A.Q.; Singh, B.; Hasan, M. Power conditioning of Distributed Generation system using Unified Power Quality Conditioner. In *Proceedings of the 2015 Annual IEEE India Conference (INDICON)*, New Delhi, India, 17–19 December 2015; pp. 1–5.
39. Gayatri, M.T.L.; Parimi, A.M.; Kumar, A.P. Application of Dynamic Voltage Restorer in microgrid for voltage sag/swell mitigation. In *Proceedings of the 2015 IEEE Power, Communication and Information Technology Conference (PCITC)*, Bhubaneswar, India, 15–17 October 2015; pp. 750–755.
40. Najy, W.K.A.; Zeineldin, H.H.; Woon, W.L. Optimal protection coordination for microgrids with grid-connected and islanded capability. *IEEE Trans. Ind. Electron.* **2013**, *60*, 1668–1677. [[CrossRef](#)]
41. Hosseini, S.A.; Abyaneh, H.A.; Sadeghi, S.H.H.; Razavi, F.; Nasiri, A. An overview of microgrid protection methods and the factors involved. *Renew. Sustain. Energy Rev.* **2016**, *64*, 174–186. [[CrossRef](#)]
42. Valov, M.; Nuschke, M. Implementation and Dynamic Validation of an Adaptive Protection System during Microgrid Restoration. *Proceeding of the 2018 International Conference and Exposition on Electrical And Power Engineering (EPE)*, Iasi, Romania, 18–19 October 2018; pp. 264–269. [[CrossRef](#)]
43. Valov, M.; Merino, J. A case study of an adaptive protection scheme for the web-of-cells concept. In *Proceedings of the 2017 IEEE PES Innovative Smart Grid Technologies Conference Europe (ISGT-Europe)*, Turin, Italy, 26–29 September 2017; pp. 1–6. [[CrossRef](#)]
44. Laaksonen, H.J. Protection principles for future microgrids. *IEEE Trans. Power Electron.* **2010**, *25*, 2910–2918. [[CrossRef](#)]
45. Che, L.; Khodayar, M.E.; Shahidehpour, M. Adaptive Protection System for Microgrids: Protection practices of a functional microgrid system. *IEEE Electr. Mag.* **2014**, *2*, 66–80. [[CrossRef](#)]
46. Parhizi, S.; Lotfi, H.; Khodaei, A.; Bahramirad, S. State of the Art in Research on Microgrids: A Review. *IEEE Access* **2015**, *3*, 890–925. [[CrossRef](#)]
47. Hooshyar, A.; Iravani, R. Microgrid Protection. *Proc. IEEE* **2017**, *105*, 1332–1353. [[CrossRef](#)]
48. Stadler, M.; Cardoso, G.; Mashayekh, S.; Forget, T.; DeForest, N.; Agarwal, A.; Schönbein, A. Value streams in microgrids: A literature review. *Appl. Energy* **2016**, *162*, 980–989. [[CrossRef](#)]
49. Ramamoorthy, M.; Venkata Naga Lakshmi Lalitha, S. Microgrid Protection Systems. In *Micro-Grids—Applications, Operation, Control and Protection*; IntechOpen: London, UK, 2019; ISBN 978-1-78984-061-2.

50. Majzoobi, A.; Khodaei, A. Application of microgrids in providing ancillary services to the utility grid. *Energy* **2017**, *123*, 555–563. [CrossRef]
51. Contreras, S.F.; Cortes, C.A.; Myrzik, J.M.A. Optimal microgrid planning for enhancing ancillary service provision. *J. Mod. Power Syst. Clean Energy* **2019**, *7*, 862–875. [CrossRef]
52. Yuen, C.; Oudalov, A. The Feasibility and Profitability of Ancillary Services Provision from Multi-MicroGrids. In Proceedings of the 2007 IEEE Lausanne Powertech, Lausanne, Switzerland, 1–5 July 2007; pp. 598–603.
53. Palizban, O.; Kauhaniemi, K.; Guerrero, J.M. Microgrids in active network management—Part I: Hierarchical control, energy storage, virtual power plants, and market participation. *Renew. Sustain. Energy Rev.* **2014**, *36*, 428–439. [CrossRef]
54. Basu, A.K.; Chowdhury, S.P.; Chowdhury, S.; Paul, S. Microgrids: Energy management by strategic deployment of DERs—A comprehensive survey. *Renew. Sustain. Energy Rev.* **2011**, *15*, 4348–4356. [CrossRef]
55. Sinha, A.; Basu, A.K.; Lahiri, R.N.; Chowdhury, S.; Chowdhury, S.P.; Crossley, P.A. Setting of Market Clearing Price (MCP) in Microgrid Power Scenario. In Proceedings of the IEEE Power and Energy Society 2008 General Meeting: Conversion and Delivery of Electrical Energy in the 21st Century, PES, Pittsburgh, PA, USA, 20–24 July 2008; pp. 1–8.
56. Pilo, F.; Hatziaargyriou, N.; Celli, G.; Pisano, G.; Tsikalakis, A. Economic scheduling functions to operate microgrids in liberalized energy markets. In Proceedings of the 41st International Conference on Large High Voltage Electric Systems 2006, CIGRE 2006, Paris, France, 27 August–1 September 2006.
57. Directive 2009/72/EC. Directive 2009/72/EC of the European Parliament and of the Council of 13 July 2009, Concerning Common Rules for the Internal Market in Electricity and Repealing Directive 2003/54/EC. 2009. Available online: <https://eur-lex.europa.eu/legal-content/EN/TXT/HTML/?uri=CELEX:32009L0072&rid=1> (accessed on 1 March 2021).
58. Elsen, R.; Aouini, B.; Barócsi, Z.; Bonnet, T.; Bouzoualegh, A.; Compter, H.J.; Galindo, J.; Gomes, M.; Ioanitescu, C.; Jacquet, R.; et al. *Ancillary Services Unbundling Electricity Products—An Emerging Market*; Union of the Electricity Industry—EURELECTRIC: Brussels, Belgium, 2004.
59. Yu, X.; Tolbert, L.M. Ancillary Services Provided from DER with Power Electronics Interface. In Proceedings of the 2006 IEEE Power Engineering Society General Meeting, PES, Montreal, QC, Canada, 18–22 June 2006; p. 8.
60. Kueck, J.D.; Kirby, B.J.; Tolbert, L.M.; Rizy, D.T. Voltage Regulation: Tapping Distributed Energy Resources: Reactive Power Is the Key to an Efficient and Reliable Grid. *Public Util. Fortn.* **2004**, *142*, 47–51.
61. Campbell, J.B.; King, T.J.; Ozpineci, B.; Rizy, D.T.; Tolbert, L.M.; Xu, Y.; Yu, X. *Ancillary Services Provided from DER*; Oak Ridge National Lab.(ORNL): Oak Ridge, TN, USA, 2005.
62. Rebours, Y. A Comprehensive Assessment of Markets for Frequency and Voltage Control Ancillary Services. Ph.D. Thesis, University of Manchester, Manchester, UK, 2008.
63. Billinton, R.; Allan, R.N. *Reliability Evaluation of Power Systems*, 2nd ed.; Plenum Press: New York, NY, USA, 1996; ISBN 978-1-4899-1862-8.
64. IEEE. *IEEE Std 1159-1995—IEEE Recommended Practice for Monitoring Electric Power Quality*; IEEE Std: Piscataway, NJ, USA, 1995.
65. Hirst, E.; Kirby, B. *Creating Competitive Markets for Ancillary Services*; Oak Ridge National Laboratory Energy Division: Oak Ridge, TN, USA, 1997.
66. Kuzle, I.; Bošnjak, D.; Tešnjak, S. An overview of ancillary services in an open market environment. In Proceedings of the 2007 Mediterranean Conference on Control and Automation, MED, Athens, Greece, 27–29 June 2007.
67. Bidram, A.; Davoudi, A. Hierarchical structure of microgrids control system. *IEEE Trans. Smart Grid* **2012**, *3*, 1963–1976. [CrossRef]
68. Shayeghi, H.; Shahryari, E.; Moradzadeh, M.; Siano, P. A survey on microgrid energy management considering flexible energy sources. *Energies* **2019**, *12*, 2156. [CrossRef]
69. Meyabadi, A.F.; Deihimi, M.H. A review of demand-side management: Reconsidering theoretical framework. *Renew. Sustain. Energy Rev.* **2017**, *80*, 367–379. [CrossRef]
70. Gandhi, O.; Rodriguez-Gallegos, C.D.; Srinivasan, D. Review of optimization of power dispatch in renewable energy system. In Proceedings of the IEEE PES Innovative Smart Grid Technologies, Melbourne, VIC, Australia, 28 November–1 December 2016; pp. 250–257. [CrossRef]
71. Sobri, S.; Koohi-Kamali, S.; Rahim, N.A. Solar photovoltaic generation forecasting methods: A review. *Energy Convers. Manag.* **2018**, *156*, 459–497. [CrossRef]
72. Fallah, S.N.; Deo, R.C.; Shojafar, M.; Conti, M.; Shamshirband, S. Computational intelligence approaches for energy load forecasting in smart energy management grids: State of the art, future challenges, and research directions. *Energies* **2018**, *11*, 596. [CrossRef]
73. Jiang, L.; Hu, G. A Review on Short-Term Electricity Price Forecasting Techniques for Energy Markets. In Proceedings of the 2018 15th International Conference on Control, Automation, Robotics and Vision (ICARCV), Singapore, 18–21 November 2018; pp. 937–944. [CrossRef]
74. Palensky, P.; Dietrich, D. Demand side management: Demand response, intelligent energy systems, and smart loads. *IEEE Trans. Ind. Inform.* **2011**, *7*, 381–388. [CrossRef]
75. Antonanzas, J.; Osorio, N.; Escobar, R.; Urraca, R.; Martinez-de-Pison, F.J.; Antonanzas-Torres, F. Review of photovoltaic power forecasting. *Sol. Energy* **2016**, *136*, 78–111. [CrossRef]
76. Molderink, A.; Bakker, V.; Hurink, J.L.; Smit, G.J.M. Comparing demand side management approaches. In Proceedings of the IEEE PES Innovative Smart Grid Technologies Conference Europe, Berlin, Germany, 14–17 October 2012; pp. 1–8. [CrossRef]

77. Han, X.; Heussen, K.; Gehrke, O.; Bindner, H.W.; Kroposki, B. Taxonomy for Evaluation of Distributed Control Strategies for Distributed Energy Resources. *IEEE Trans. Smart Grid* **2018**, *9*, 5185–5195. [\[CrossRef\]](#)
78. Vashishtha, S.; Ramachandran, M. Multicriteria evaluation of demand side management (DSM) implementation strategies in the Indian power sector. *Energy* **2006**, *31*, 2210–2225. [\[CrossRef\]](#)
79. Gehrke, O.; Isleifsson, F. An aggregation friendly information model for demand side resources. In Proceedings of the IEEE Local Computer Network Conference Lcn, Denver, CO, USA, 10–14 October 2010; pp. 1019–1023. [\[CrossRef\]](#)
80. Kuster, C.; Rezgui, Y.; Mourshed, M. Electrical load forecasting models: A critical systematic review. *Sustain. Cities Soc.* **2017**, *35*, 257–270. [\[CrossRef\]](#)
81. Nowotarski, J.; Weron, R. Recent advances in electricity price forecasting: A review of probabilistic forecasting. *Renew. Sustain. Energy Rev.* **2018**, *81*, 1548–1568. [\[CrossRef\]](#)
82. Alfares, H.K.; Nazeeruddin, M. Electric load forecasting: Literature survey and classification of methods. *Int. J. Syst. Sci.* **2002**, *33*, 23–34. [\[CrossRef\]](#)
83. Kosek, A.M.; Costanzo, G.T.; Bindner, H.W.; Gehrke, O. An overview of demand side management control schemes for buildings in smart grids. In Proceedings of the 2013 IEEE International Conference on Smart Energy Grid Engineering (SEGE), Oshawa, ON, Canada, 28–30 August 2013; pp. 1–9. [\[CrossRef\]](#)
84. Wang, S.; Li, Z.; Wu, L.; Shahidehpour, M.; Li, Z. New metrics for assessing the reliability and economics of microgrids in distribution system. *IEEE Trans. Power Syst.* **2013**, *28*, 2852–2861. [\[CrossRef\]](#)
85. Zhang, W.; Chen, G.; Dong, Z.Y. Demand side management given distributed generation and storage: A comparison for different pricing and regulation scenarios. In Proceedings of the 10th International Conference on Advances in Power System Control, Operation & Management (APSCOM 2015), Hong Kong, China, 8–12 November 2015; pp. 1–6.
86. Paetz, A.; Kaschub, T.; Jochem, P.; Fichtner, W. Demand Response with Smart Homes and Electric Scooters: An Experimental Study on User Acceptance Previous Research. In Proceedings of the American Council for an Energy Efficient Economy Summer Study on Energy Efficiency in Buildings, Pacific Grove, CA, USA, 12–17 August 2012; pp. 224–236.
87. Samadi, P.; Mohsenian-Rad, H.; Schober, R.; Wong, V.W.S. Advanced demand side management for the future smart grid using mechanism design. *IEEE Trans. Smart Grid* **2012**, *3*, 1170–1180. [\[CrossRef\]](#)
88. Alwan, H.O.; Abdelwahed, S. Demand Side Management- Literature Review and Performance Comparison. In Proceedings of the 2019 11th International Conference on Computational Intelligence and Communication Networks (CICN), Honolulu, HI, USA, 3–4 January 2019; pp. 93–102. [\[CrossRef\]](#)
89. Rangel, C.M.; Mascarella, D.; Joos, G. Real-time implementation & evaluation of grid-connected microgrid energy management systems. In Proceedings of the 2016 IEEE Electrical Power and Energy Conference (EPEC), Ottawa, ON, Canada, 12–14 October 2016; pp. 1–6. [\[CrossRef\]](#)
90. Li, Z.; Shahidehpour, M.; Aminifar, F. Cybersecurity in Distributed Power Systems. *Proc. IEEE* **2017**, *105*, 1367–1388. [\[CrossRef\]](#)
91. Khraisat, A.; Gondal, I.; Vamplew, P.; Kamruzzaman, J. Survey of intrusion detection systems: Techniques, datasets and challenges. *Cybersecurity* **2019**, *2*, 384. [\[CrossRef\]](#)
92. Kummerow, A.; Rösch, D.; Monsalve, C.; Nicolai, S.; Bretschneider, P. Challenges and opportunities for phasor data based event detection in transmission control centers under cyber security constraints. In Proceedings of the IEEE Milan PowerTech, Milano, Italy, 23–27 June 2019; pp. 3–8.
93. Khurana, H.; Hadley, M.; Lu, N.; Frincke, D.A. Smart-grid security issues. *IEEE Secur. Priv.* **2010**, *8*, 81–85. [\[CrossRef\]](#)
94. Ryan, M.D. Cloud computing security: The scientific challenge, and a survey of solutions. *J. Syst. Softw.* **2013**, *86*, 2263–2268. [\[CrossRef\]](#)
95. Metke, A.R.; Ekl, R.L. Security Technology for Smart Grid Networks. *IEEE Trans. Smart Grid* **2010**, *1*, 99–107. [\[CrossRef\]](#)
96. Kuntze, N.; Rudolph, C.; Bente, I.; Vieweg, J.; von Helden, J. Interoperable device identification in smart-grid environments. In Proceedings of the 2011 IEEE Power and Energy Society General Meeting, Detroit, MI, USA, 24–28 July 2011; pp. 1–7.
97. Lauer, H.; Salehi, A.; Rudolph, C.; Nepal, S. User-centered attestation for layered and decentralized systems. In Proceedings of the Workshop on Decentralized IoT Security and Standards (DISS), San Diego, CA, USA, 18 February 2018.
98. Rehmani, M.H.; Davy, A.; Jennings, B.; Assi, C. Software Defined Networks-Based Smart Grid Communication: A Comprehensive Survey. *IEEE Commun. Surv. Tutor.* **2019**, *21*, 2637–2670. [\[CrossRef\]](#)
99. McGraw, G. Software security. *IEEE Secur. Priv.* **2004**, *2*, 80–83. [\[CrossRef\]](#)
100. Klein, G.; Elphinstone, K.; Heiser, G.; Andronick, J.; Cock, D.; Derrin, P.; Elkaduwe, D.; Engelhardt, K.; Kolanski, R.; Norrish, M.; et al. seL4: Formal verification of an OS kernel. In Proceedings of the ACM SIGOPS 22nd Symposium on Operating Systems Principles; Big Sky, MT, USA, 11–14 October 2009; pp. 207–220.
101. Godefroid, P.; Levin, M.Y.; Molnar, D. *SAGE: Whitebox Fuzzing for Security Testing*; ACM: New York, NY, USA, 2012; Volume 55.
102. Fries, S.; Hof, H.J.; Seewald, M. Enhancing IEC 62351 to Improve Security for Energy Automation in Smart Grid Environments. In Proceedings of the 2010 Fifth International Conference on Internet and Web Applications and Services, Barcelona, Spain, 9–15 May 2010; pp. 135–142.
103. Liu, J.; Xiao, Y.; Li, S.; Liang, W.; Chen, C.L.P. Cyber Security and Privacy Issues in Smart Grids. *IEEE Commun. Surv. Tutor.* **2012**, *14*, 981–997. [\[CrossRef\]](#)
104. Dehghanpour, K.; Wang, Z.; Wang, J.; Yuan, Y.; Bu, F. A Survey on State Estimation Techniques and Challenges in Smart Distribution Systems. *IEEE Trans. Smart Grid* **2019**, *10*, 2312–2322. [\[CrossRef\]](#)

105. Valverde, G. Uncertainty and state estimation of power systems. Ph.D. Thesis, University of Manchester, Manchester, UK, 2012.
106. Ron, R.; Pillitterie, V.; Graubart, R.; Bodeau, D.; McQuaid, R. *Developing Cyber Resilient Systems: A Systems Security Engineering Approach*; National Institute of Standards and Technology: Gaithersburg, MD, USA, 2019.
107. Temple, W.G.; Chen, B.; Tippenhauer, N.O. Delay makes a difference: Smart grid resilience under remote meter disconnect attack. In Proceedings of the 2013 IEEE International Conference on Smart Grid Communications (SmartGridComm), Vancouver, BC, Canada, 21–24 October 2013; pp. 462–467.
108. Panteli, M.; Trakas, D.N.; Mancarella, P.; Hatziargyriou, N.D. Boosting the power grid resilience to extreme weather events using defensive islanding. *IEEE Trans. Smart Grid* **2016**, *7*, 2913–2922. [[CrossRef](#)]
109. Goldman, H.; McQuaid, R.; Picciotto, J. Cyber resilience for mission assurance. In Proceedings of the 2011 IEEE International Conference on Technologies for Homeland Security (HST), Boston, MA, USA, 15–17 November 2011; pp. 236–241.
110. Pillitteri, V.Y.; Brewer, T.L. *Guidelines for Smart Grid Cybersecurity*; National Institute of Standards and Technology: Gaithersburg, MD, USA, 2014.
111. Vugrin, E.D.; Warren, D.E.; Ehlen, M.A.; Camphouse, R.C. A framework for assessing the resilience of infrastructure and economic systems. In *Sustainable and Resilient Critical Infrastructure Systems*; Springer: Berlin, Germany, 2010; pp. 77–116.
112. Dong, X.; Lin, H.; Tan, R.; Iyer, R.K.; Kalbarczyk, Z. Software-defined networking for smart grid resilience: Opportunities and challenges. In *Proceedings of the Proceedings of the 1st ACM Workshop on Cyber-Physical System Security*; Singapore, 14–17 April 2015, pp. 61–68.
113. Björck, F.; Henkel, M.; Stirna, J.; Zdravkovic, J. Cyber Resilience—Fundamentals for a Definition. In *New Contributions in Information Systems and Technologies*; Springer International Publishing: New York, NY, USA, 2015; pp. 311–316. ISBN 978-3-319-16486-1.
114. Xu, M.; Huber, M.; Sun, Z.; England, P.; Peinado, M.; Lee, S.; Marochko, A.; Mattoon, D.; Spiger, R.; Thom, S. Dominance as a New Trusted Computing Primitive for the Internet of Things. In Proceedings of the 2019 IEEE Symposium on Security and Privacy (SP), San Francisco, CA, USA, 20–22 May 2019; pp. 1415–1430.
115. Kumar, P.; Lin, Y.; Bai, G.; Pavard, A.; Dong, J.S.; Martin, A. Smart grid metering networks: A survey on security, privacy and open research issues. *IEEE Commun. Surv. Tutor.* **2019**, *21*, 2886–2927. [[CrossRef](#)]
116. Li, F.; Luo, B.; Liu, P. Secure information aggregation for smart grids using homomorphic encryption. In Proceedings of the 2010 First IEEE international conference on smart grid communications, Gaithersburg, MA, USA, 4–6 October 2010; pp. 327–332.
117. Mengelkamp, E.; Notheisen, B.; Beer, C.; Dauer, D.; Weinhardt, C. A blockchain-based smart grid: Towards sustainable local energy markets. *Comput. Sci. Dev.* **2018**, *33*, 207–214. [[CrossRef](#)]
118. Kotsampopoulos, P.; Hatziargyriou, N.; Bletterie, B.; Lauss, G. Review, analysis and recommendations on recent guidelines for the provision of ancillary services by Distributed Generation. In Proceedings of the 2013 IEEE International Workshop on Intelligent Energy Systems (IWIES), Vienna, Austria, 14 November 2013; pp. 185–190. [[CrossRef](#)]
119. Neves, D.; Pina, A.; Silva, C.A. Comparison of different demand response optimization goals on an isolated microgrid. *Sustain. Energy Technol. Assess.* **2018**, *30*, 209–215. [[CrossRef](#)]
120. IEEE 2030.8-2018. *IEEE Standard for the Testing of Microgrid Controllers*; IEEE Std: Piscataway, NJ, USA, 2018.
121. Solanki, B.V.; Bhattacharya, K.; Canizares, C.A. A Sustainable Energy Management System for Isolated Microgrids. *IEEE Trans. Sustain. Energy* **2017**, *8*, 1507–1517. [[CrossRef](#)]
122. Unamuno, E.; Barrena, J.A. Hybrid ac/dc microgrids—Part I: Review and classification of topologies. *Renew. Sustain. Energy Rev.* **2015**, *52*, 1251–1259. [[CrossRef](#)]